

DESCRIPTION

Free Flow is a dual-purpose synergistic blend of cultured bacteria, enzymes, detergents, and deodorants that will digest and liquefy organic waste, paper, detergent, grease, hair, fat, and other wastes to free drains, pipes, and grease traps. Free Flow is the perfect alternative to dangerous chemicals, breaking down organic waste safely and effectively. Restores normal biological activity to septic tanks, sewer treatment plants, and sludge lagoons.

FIRST-AID

Eyes: Flush with copious amounts of water lifting lids and removing contact lenses to ensure complete irrigation—get medical attention.

Skin: Flush with water and then wash with soap and water, launder contaminated clothing before reuse—get medical attention if irritation persists.

Inhalation: Remove to fresh air and assist breathing as necessary—get medical attention.

Ingestion: Wash out mouth with water. If conscious, give small quantities of water to drink. Do not induce vomiting—get medical attention.

CAUTION

Please refer to the SDS for more detailed precautionary measures, handling instructions and emergency procedures.

DIRECTIONS

Grease Traps: For traps less than 20 cu. ft. capacity, add 4-5 oz. Free Flow daily by pouring in a sink or pipeline closest to the trap when traps are used the least. After adding, flush down with a cup of lukewarm water. For grease traps larger than 20 cu. ft., add 8-10 oz. daily.

Septic Tanks: Add 1 pint per 25 cu. ft. capacity for the initial treatment. Thereafter, use 8 oz. per week. Pour directly into toilet and flush. If septic tank has become clogged and odorous, add 1-gallon Free Flow directly to the tank through the manhole.

Municipal Sewage Treatment Systems Trickling Filters: Use 5-6 gallons per million gallons of daily flow. For preventative maintenance, use 2 gallons per MGD weekly to maintain proper operations.

Sludge Lagoons: Use 5-6 gallons per MGD at point of entry. Use 2 gallons per MGD each week for maintenance.

Anaerobic Sludge: Use 2 gallons per 10 cu. ft., twice weekly. Free Flow should be used after the use of a drain opener (flush system completely) for activating the natural digestive processes to prevent future clogging and/or as an odor counteractant on Hydrogen Sulfide fumes created from a chemical eating the grease.

Drain and Down Pipes: Use a minimum of 2 times weekly to a maximum of 4 times depending on the usage of the building. Add in amounts listed below. Start on the lowest floor and work up at the rate of one floor every day. Do not treat the same floor twice. When the top floor is reached continue treatment for the top floor only.

Pipe Size	Free Flow	Frequency
2"	4 oz.	2x/week
4"	8 oz.	2x/week
6"	12 oz.	2x/week
8"	16 oz.	2x/week

HMIS SYMBOL



Health	1
Fire	0
Reactivity	0
Personal Protection	